



BERGRIVIER MUNICIPALITY

SUPPLY CHAIN MANAGEMENT

Enquiries: Mr. I. Saunders
E-mail: saundersi@bergmun.org.za

Ref: Tender no. 8.3.2 – 2021 (MN5 – 2021)

Tel: (022) 022 913 6038

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM:

TENDER 8/3/2-2021 MN5/2021: Refurbishment and replacement of equipment at Velddrif Waste Water Treatment Works

ADDENDUM NO. 3:

Amended specifications for fencing

Gate posts	2 x 2.6m x 100mm x 100mm x 3mm Galvanized and powder coated or painted green.
Gate	1 x 5.0m x 2.05m single leaf gate to match the fence. Gate frame must be made of 50mm x 2mm square tubing, outer frame for each leaf and on vertical for each leaf, including 3 x 30mm x 5mm cover plates per leaf with 100mm x 30mm bullet hinges. The gate will have one drop bolt and sliding bolt that can be locked with a padlock.



BERGRIVIER MUNICIPALITY

MUNICIPAL MANAGER

DATE:

Note: Confirmation to the addendum

CONFIRMATION

I (Name and Surname of designated person) hereby declare on behalf of (Company's name),

That I take note of the above changes in the bidding documentation and that my offer will incorporate the changes.

Address: Tel no.:
..... Fax no.:
.....

Signature of bidder: Date:

This document must to be completed by the bidder (above) and submitted with his offer.