



BERGRIVIER MUNICIPALITY

SUPPLY CHAIN MANAGEMENT

Enquiries: Mr. I. Saunders
saundersi@bergmun.org.za

Ref: Tender 8.3.40 – 2020 (MN 122 – 2020)

Tel: (022) 022 913 6038 E-mail:

As per e-mail:

Dear Sir /Madam

NOTICE TO BIDDERS

ADDENDUM:

TENDER 8/3/40-2020 MN122-2020: RENOVATION AND REPAIRS AT SWIMMING POOL IN PORTERVILLE

ADDENDUM NO. 1:

At the compulsory clarification meeting held on Wednesday, 02 September 2020, it was resolved as follows:

1. Water in swimming pool

- The municipality will pump out the water in the swimming pool.

2. Fibreglass line

- The fibreglass lining must be the full depth of the pool. This must be from the surface to the top edge of the pool.

3. Balancing of water

- The balancing and chemicalization of the water after the relining of the pool is the responsibility of the tenderer.

4. Tissue mosaic

- The tissue mosaic must be the standard colour and 110mm in width.

5. Coping stones

- All broken coping stones must be replaced.



BERGRIVIER MUNICIPALITY

6. Revised Pricing Schedule

- Please note the pricing schedule is hereby revised.

	TENDER AMOUNT
Fibreglass line pool in Standard Pool Blue including tissue mosaic	R
Coping Stone replacement	R
Provisional Sum	R 10 000
Total (VAT Inclusive)	R

MUNICIPAL MANAGER

DATE:

Note: Confirmation to the addendum

CONFIRMATION

I (Name and Surname of designated person) hereby declare on behalf of (Company's name),

That I take note of the above changes in the bidding documentation and that my offer will incorporate the changes.

Address: Tel no.:
..... Fax no.:
.....

Signature of bidder: Date:

This document must to be completed by the bidder (above) and submitted with his offer.